

SIL



Functional Safety Certificate

No. 1N191223.SBOWD19

Technical Construction File no. SIL-WSKATD896

Certificate's Holder: Senex Branch Office of Shenzhen Wanxun Automation Co., Ltd.
102, first floor, no.600-2, Second Guangshan Road, Tianhe District, Guangzhou, Guangdong Province, China

Product: Pressure Transmitter
Model(s): DG/DP/DS/DK Series

Standard: Has been assessed per the relevant requirements of: IEC 61508:2010 Parts 1-7
And meets requirements providing a level of integrity to:
Systematic Capability: SC 2 (SIL 2 Capable)
Random Capability: Type A Element
SIL 2 @ HFT= 0; SIL 3@ HFT=1; Route 2_H
PFD_{avg} and Architecture Constraints must be verified each application.

* Safety Function:

The temperature transmitter uses the thermocouple and the thermal resistance as the temperature measuring element. The output signal from the temperature measuring element is sent to the transmitter module and converted into the current letter, the voltage signal and the digital signal output.

* Is suitable to be safety function according to the description and the configuration defined in Annex I.

Verification Mark:



The Verification Mark can be affixed on the product. It is NOT permitted to alter the Verification Mark in any way

Remark: This SIL Verification of Compliance has been issued on a voluntary basis. ECM confirms that a Test Report is existent for the above listed product(s) and found to meet the requirements of above standards for application in safety related system up to Safety Level of **SIL 2**.

The unit must be properly designed into a Safety Instrument Function as per the requirements in the Safety Manual. The Verification Mark shown above can be affixed on the product. It is NOT permitted to alter the Verification Mark in any way. In addition the Verification's Holder is NOT allowed to transfer the Verification to third parties. This certificate can be checked for validity at www.entecerma.it

Date of issue 24 December 2019

Expiry date 23 December 2024

**Chief Manager
Marco Morino**

**Deputy Manager
Amanda Payne**

Ente Certificazione Macchine

Via Cà Bella, 243 - 40053 Valsamoggia Loc. Castello di Serravalle (Bo) Italy

+39.0516705141 +39.0516705156 info@entecerma.it www.entecerma.it



Annex I

No. 1N191223.SBOWD19

Technical Construction File no. SIL-WSKATD896

- The use of the product must obey the required rules to conservation of SIL3 properties. These rules are recalled in the §6 of the Assessment Report reference.
- The product version of hardware components used for validation and type tests are the following:

Component	Model
Pressure Transmitter	DG/DP/DS/DK Series

- Acceptable environmental constraints for the system are stated in the safety manual. These elements must be checked for each integration of the product.
- The SIL 2 capable certified Safety Instrumented Function of product is the following:
 - SF1: To Close on demand.
 - SF2: To Open on demand.
- Hypothesis used for calculations are presented here under: The mode of operation is Low demand, which means less than 1 trip demand each year;

Component architecture	SIL Capability	Demand frequency	PFD
1oo1 configuration	SIL2	Low	9.26E-04
1oo2 configuration	SIL3	Low	2.08E-04

Safety function	Failure rate	Undetected dangerous failure rate	Tests intervals	MTR
SF1	4.53E-05	4.17E-07	11months	48h
SF2	4.68E-05	4.21E-07	11months	48h

- The Safety Integrated Level of the safety function using the product shall be calculated taking into account the characteristics of the whole system.